



2800 Guthrie Road Dayton, Ohio 45417 (937) 333-1502 / Fax (937) 333-1826 www.daytonohio.gov

## CITY OF DAYTON - DIVISION OF WATER RECLAMATION INDUSTRIAL PRETREATMENT PROGRAM DENTAL DISCHARGERS WITH AMALGAM PROCESS WASTEWATER ONE-TIME COMPLIANCE REPORT

## **Instructions**

This form is for dental dischargers that place or remove dental amalgam. Dental dischargers that do not place or remove dental amalgam shall complete and submit this form "City of Dayton- Division of Water Reclamation Industrial Pretreatment Program - Dental Dischargers without Amalgam Process Wastewater One-Time Compliance Report"

This form may be completed by a third party on behalf of the dental office, but the submission must be signed by at least one of the following (check the box that applies):

A responsible corporate officer if the dental office is a corporation;
A general partner or proprietor if the dental office is a partnership or sole proprietorship; or
A duly authorized representative of the responsible corporate officer, or general partner or proprietor.

Mail this completed form to:

City of Dayton - Water Reclamation Facility
Industrial Pretreatment Program
2800 Guthrie Road
Dayton, Ohio 45417

Attn: Jerome Wright or Inez Preyor

This completed form is to be submitted by the following deadlines (check the box that applies):

October 20, 2020, for facilities which began discharging on or prior to July 14, 2017;
Within 90 days after first dental discharge, if the first dental discharge began after July 14, 2017; or
Within 90 days after a transfer of ownership.

3)	Mailing Address:   Same as physical address		
4)	Contact Information		
	Phone number:	Email Address:	
5)	Name(s) of Owner(s):		
	Owner First and Last Name	Approximate Ownership Date	
		•	
6)	Name(s) of Maintenance Operator(s) which ensures proper operation and maintenance activities, as described in Item 8 of this form:		
	Maintenance Operator First and Last Name	Employer / Third-Party Service Provider	

If there is not a third-party service provider, attach a brief description of the practices employed by the facility to ensure the proper operation and maintenance in accordance with Item 8 (§ 441.30 or § 441.40).

7) Description of Operations at	· ·			
<ul><li>a. Total Number of Chairs</li><li>b. Total Number of Chairs</li></ul>		zam May Bo Brosont	in Deculting Masternator	
c. Does the Facility Curre		· ·		
☐ Yes ☐ No	intry mave minargam is	iemoving omit(s) matt		
d. If "Yes" to Question 7.	c, fill out the followin	g table for <i>each</i> ama	gam removing unit:	
Unit Description	Make	Model	Year of Installation	
	L			
			1	
	it that is <u>not</u> an Amal	gam Separator, attac	h information which demonstra	ites
that:	ciancy is at least 05%	4 of the mass of solid	s from all amalgam wastewater,	
	val efficiency must b		s irom an amaigam wastewater	,
	•		on a dry weight basis;	
□ Demonstrat	ed at the maximum v	vater flow rate throu	gh the device as established by	the
device manu	ıfacturer's instruction	ns of use;		
	• • •	erformance of three s	•	
	•		that meets the following partic	le
	•	•	istribution of particle sizes:	_L_
⊔ 60% by m 500 μm si		pass through a 3,150	µm sieve but do not pass throu	gn a
•		nass through a 500 w	m sieve but do not pass through	าล
100 μm s		pass tinoagna soo μι	sieve bat ao not pass tinoagi	. u
•		pass through a 100 μ	m sieve.	
·				

do <u>not</u> currently have an amalgam sep  By June 14, 2027, or when the amalga	im separator is replaced (whichever is sooner), for facilities			
amalgam separator before June 14, 20				
Immediately Upon Discharge, for facil	ities that began discharging wastewater after July 14, 2017.			
The amalgam-removal unit shall be:				
	n discharge rate of amalgam process wastewater; s in 40 CFR 441.30(a)(1)(i) or 441.30(a)(2)(i-ii), unless it was			
·	s manual providing instructions for use including the enance activities;			
· · · · · · · · · · · · · · · · · · ·	anufacturer's operating manual to ensure proper operation confirm that all amalgam process wastewater is flowing rtion of the unit(s);			
e. Repaired consistent with manufacture requirements in Item 8.a-b as soon a	rer instructions or replaced with a unit that meets the as possible, but no later than 10 business days after a ntal discharger, or an agent or representative of the dental			
f. Maintained and replaced in accorda manufacturer's operating manual or level (as specified by the manufactu				
Signature	Name (Printed)			
Title	Date			

9) I certify that as this facility is in operation, or until ownership is transferred, this facility (or an agent or representative of the facility) must maintain this One-Time Compliance Report. This facility shall also maintain the manufacturer's operating manual for all current amalgam-removing devices. These documents shall be available for inspection in either physical or electronic form.

In addition, this facility (or an agent or representative of this facility) shall retain and make available for inspection the following physical or electronic records for a minimum of three years:

- a. Documentation of date(s), person(s) conducting the inspection, and results of each inspection of the amalgam-removing unit(s), and a summary of follow-up actions, if needed;
- b. Documentation of amalgam retaining container or equivalent container replacement (including the date, as applicable);
- c. Documentation of all dates that collected dental amalgam is picked up or shipped for proper disposal in accordance with 40 CFR 261.5(g)(3), and the name of the permitted or licensed treatment, storage or disposal facility receiving the amalgam retaining containers;
- d. Documentation of any repair or replacement of amalgam separator or equivalent device, including the date, person(s) making the repair/replacement, and a description of the repair/replacement (including make or model).

Signature		Name (Printed)	
Title		Date	
441.3 a. b	O(b) or § 441.40(b):  This facility will not discharge waste a treatment works. Waste amalgam in traps, screens, vacuum pump filters, on Dental unit water lines, chair-side trawastewater to a sanitary sewer syste with oxidizing or acidic cleaners that	ollowing Best Management Practices (BMPs) specified in § malgam to the sanitary sewer lines or publicly owned cludes, but is not limited to, dental amalgam from chair-side dental tools, cuspidors, or collection devices. ps, and vacuum lines that discharge amalgam process m or publicly owned treatment works must not be cleaned have a pH lower than 6 or greater than 8. Oxidizing or acidic to bleach, chlorine, iodine, and peroxide.	
Signature		Name (Printed)	

Date

Title

11) I certify under penalty of law that I have personally examined and am familiar with the inform report and all attachments. Based on my inquiry of those persons immediately responsible for the information contained in the report, I believe that the information is true, accurate, and compared am aware there are significant penalties for submitting false information, including the possible and imprisonment.				
Signature	Name (Printed)			
Title	Date			

Keep a signed copy of this form in your file for the duration of ownership.